



Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, SUITE 4, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.777.9587

[HTTP://DPP.VI.GOV](http://DPP.VI.GOV)



February 26, 2018

AMENDMENT #3 – RFP-005-2018 (P) Design Build for Temporary Educational Facilities on the islands of St. Croix, St. John and St. Thomas, U.S. Virgin Islands

DELETE: Question 18:

Response: Confirmed. You may assume 2000 PSF soil bearing capacity for the Virgin Islands.

Question 20:

Response: Confirmed. Use the Uniform Plumbing Code.

INSERT: Question 18:

Corrected Response: You may assume 2000 PSF soil bearing capacity for the Virgin Islands.

Question 20:

Corrected Response: Use the Uniform Plumbing Code.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT WITH THEIR BID PROPOSAL.